



INFORMATIONAL BULLETIN

PARTS & SERVICE DEPARTMENT

300 Maddox Simpson Pkwy
Lebanon, Tennessee 37090
615-889-8900 Fax: 615-882-2963
www.Lochinvar.com

Date: March 24, 2009

Bulletin Number: 2009-05 I

TO: Manufacturers' Representatives, District Sales Managers, Regional Managers, Technical & Customer Service Personnel, Service Agents, Sales & Marketing Personnel

SUBJECT: Wall Mount Knight Boilers Using 2 Inch Flues (50, 80, and 105 models)

We have recently received several inquiries concerning the use of 2 inch PVC vent material on Wall Mount Knight Boilers. A two inch flue is approved for use with Knight Wall Mount Boilers. **When installing a 2 inch flue it is important to remember the first seven equivalent feet of vent piping must be CPVC.**

The Installation and Operation Manual, as well as the website version for the Knight Wall Mount Boiler, has been updated to include information on installing two inch flues. This information is noted on page 14, "**the first 7 equivalent feet of venting must be CPVC**".

Please note this change for your records and future reference. Should you have any questions, please contact Technical Services at 1-800-722-2101.