



INFORMATIONAL BULLETIN

PARTS & SERVICE DEPARTMENT

300 Maddox Simpson Pkwy
Lebanon, Tennessee 37090
615-889-8900 Fax: 615-547-1003
www.Lochinvar.com

Date: 7/9/04

Bulletin Number: 2004-09I

TO: Manufacturers' Reps, DSM, RSM, Tech Service, Customer Service, Service Agents

SUBJECT: CP501-751 Temperature Gauges

Between December 2003 and June 2004 the Copper-Fin II CP501-751 model units were inadvertently manufactured without temperature gauges. These gauges are used to monitor the inlet and outlet temperatures on the header of the unit.

If someone has a Copper-Fin II CP501-751 in the field and request the temperature gauges, Lochinvar will supply them. Contact the Lochinvar Customer Service Department with model and serial number of the unit. Two GTP3000 temperature gauges will be shipped for the unit.

If anyone should have questions concerning this please contact Lochinvar at 615-889-8900.