



# TECHNICAL SERVICE BULLETIN

## **PARTS & SERVICE DEPARTMENT**

300 Maddox Simpson Pkwy  
Lebanon, Tennessee 37090  
615-889-8900 Fax: 615-547-1003  
www.Lochinvar.com

*Date:* 04/17/07

*Bulletin Number:* 2007-02T

**TO:** Manufacturers' Representatives, District Sales Managers, Regional Managers, Technical & Customer Service Personnel, Service Agents and Sales & Marketing Personnel

**SUBJECT:** Information on Programmed Parts for the Intelli-Fin and Power-Fin

Circle the part numbers you need:

When placing an order for a RLY3027 (programmed XL10), RLY3026(programmed XL10 w/ I-O reset), RLY3717 (command display), RLY3723 (control board PB1500-2000 2:1), RLY3724(control board PF1500-2000 2:1), RLY3729 (control board PF1500-2000 4:1), RLY3730 (control board PB1500-2000 4:1), RLY3109 (PB501-1300 control board with I/O reset), RLY3110 (PF501-1300 control board), RLY3111 (PB501-1300 control board), SMP3000 – SMP3005, & SMP3008 – SMP3014 we need to have the following information:

Sequencer serial # \_\_\_\_\_ (If equipped)

Unit serial # \_\_\_\_\_

Unit model # \_\_\_\_\_

Original PO # \_\_\_\_\_

Does this unit have I/O reset? \_\_\_\_\_

Are changes from the original settings required? If so, what?  
\_\_\_\_\_

Which XL10 device needs to be programmed (EX: Boiler #01, Boiler #02, and Sequencer)?  
\_\_\_\_\_

If this system is using a building management system then we will also need the domain number, subnet number, and node numbers. \_\_\_\_\_

The parts above need to be programmed from the factory in order for these parts to work correctly.