



TECHNICAL SERVICE BULLETIN

PARTS & SERVICE DEPARTMENT

300 Maddox Simpson Pkwy
Lebanon, Tennessee 37090
615-889-8900 Fax: 615-547-1003
www.Lochinvar.com

Date: 7/13/04

Bulletin Number: 2004-10T

SUBJECT: FLOOD DAMAGED BOILERS AND WATER HEATERS

The recent flooding experienced in many areas of the Midwest has caused water damage to many existing boilers and water heaters. The possible damage to a flooded water heater or boiler can be extensive and present numerous safety hazards. Considering the many problems that will exist with a flooded unit, there is only one reasonable, economical and safe course of action to be followed.

IN THE INTEREST OF PUBLIC HEALTH AND SAFETY, ANY BOILER OR WATER HEATER THAT HAS BEEN SUBJECTED TO FLOODING MUST BE REPLACED.

Damage to boilers and water heaters may not be readily visible or immediately detectible; however over a period of time flooded boilers and water heaters will create dangerous conditions which could result in death, bodily harm or property damage.

Call your qualified contractor to replace your flooded boiler or water heater.