



POWER-FIN MAINTENANCE INSPECTION REPORT



| DATE | Check vent and air piping | Check relief valve | Check condensate drain system | Inspect gas/water pipes for leaks | Test low water cutoff and reset button | Inspect interior and clean | Inspect condensate system and flush | Examine venting system | Check igniter | Inspect and clean burner | Inspect and clean HEX |
|----------------------------------|---------------------------|--------------------|-------------------------------|-----------------------------------|--|----------------------------|-------------------------------------|------------------------|---------------|--------------------------|-----------------------|
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| Recommended Inspection Intervals | Monthly | Monthly | Monthly | Every Six Months | Every Six Months | Annually | Annually | Annually | Annually | Annually | Annually |

MODEL # _____ SERIAL# _____

FOR TECHNICAL QUESTIONS WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL