

July's Correct Diagnosis



Hydronic Heating Sleuth's Challenge

Answer

1. DHW piping needs an anti-scald mixing valve
2. The solar loop requires an properly sized expansion tank
3. The solar loop requires an air-separator

